

16/03/2023

**Procedure No. 23001972**  
**Goods: GATE VALVE 16"**

Please see below EAPC clarifications and replies to questions and comments received from potential participants:

EAPC replies and clarifications below become an integral part of this Tender and will force the bidders.

**EAPC Replies**

	<b>Question</b>	<b>Reply</b>
1.	<p>CAMERON are preparing the quote with provided information, however can you please advise if you can accept slab gate valve as per API6D, instead of an expanding gate valve as per API600 as indicated in the technical requirement.</p> <p>We look forward to your confirmation.</p>	<p>Not approved.</p> <p>The original specification required a parallel expanding valve. Slab Valve was not required .</p> <p>The quote should be according to the technical specification.</p>