

18 May, 2025

Procedure No. 25005132

Goods: Medium-Voltage Cables

Please see below EAPC clarifications and replies to questions and comments received from potential participants:

EAPC replies and clarifications below become an integral part of this Tender and will force the bidders.

Clarification:

The deadline for submitting proposals is postponed to 01 of June, 2025 on 11:00, Israeli time.

EAPC Replies

	Question	Reply
1.	We don't see a quantities list in the tender documents.	See in the last page of the specification.
2.	Tender document -Clause 24: Can we offer both copper and aluminum conductor? If only one is allowed, please check which type of conductor is preferred by the client.	No, only copper can be offered.
3.	Specification -On the first page, the mandatory conditions appear to imply that only European or US manufacturers are eligible to participate in this tender. Please check it and convince the client that we can get eligibility for this tender. - Taihan Group - South Korea part of the OECD. -Please ask for the format of technical data sheet to be submitted with our offer. -Please check whether we are allowed to supply 3km in single drum or multiple drums. If the client allow multiple drums, please let us know prefer length per drum.	The quote should be according to the Technical Specification. The specification states that the 3km must be supplied with three separate drums. Each 1km on a separate drum. The ends of the cable will be sealed on each drum.